

Classification Report

Number	20-003014-PR05 (NW-A01-0203-en-02)
Owner	ELVIAL S.A. Aluminium Extrusion 25th Km national road Thessaloniki 61100 Kilkis Greece
Product	Tilt and turn casement door
Designation	System: ELVIAL Essence W67 HI ² Shipping name: ELVIAL Essence W67BS HI ²
Details	Manufacturer ELVIAL S.A., Aluminium Extrusion - Kilkis; Material Aluminium system with thermal break; Type of opening Tilt and turn; Opening direction DIN left, inward opening; Overall dimensions (W x H) 900 mm x 2300 mm
Special features	Test sequence. Position of locking. Material compatibility must be taken into account. Material durability must be taken into account.

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C5/B5


Watertightness according to EN 12208:1999-11



Class: E1050

ift Rosenheim

03.09.2020



Robert Kolacny, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 20-003014-PR05 PB-A01-0203-en-02

Replaces ift-Nachweis:
20-003014-PR05 NW-A01-0203-en-01 dated 26.08.2020.

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 356-90F87